

Certificate of Compliance

Certificate Number 20070714-R21930
Report Reference 2007 September 14
Issue Date 2007 September 14

Page 1 of 1



Issued to: **Beta Industrial L L C**

Ras Al Khour Industrial Area, Ras Al Khour Rd
Dubai, United Arab Emirates

*This is to certify that
representative samples of*


Dampers for Fire Barrier and Smoke Applications
Model FDF fire damper for use in static systems.

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: ANSI/UL 555 "Fire Dampers"

Additional Information: 1-1/2 hour Fire Resistance Rating Damper Mounting Position - Vertical and
Horizontal.

**Only those products bearing the UL Classification Mark should be considered as being
covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word
"CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a
statement to indicate the extent of UL's evaluation of the product; and, the product category
name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute

Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Margaret Figueroa

Margaret Figueroa

Underwriters Laboratories Inc.