



PSD15/3/FP/9/1127

Protection & Safety Directorate
9th May 2012

*Mr. Melville Verghese
Manager (BTA)
Bahrain Trading Agencies W.L.L
P.O. Box: 30540,
Kingdom of Bahrain*

Dear Sir,

FIRE DAMPERS (MODELS: FDF & FDC)

Thank you for your submittal no. NF/03164/GM dated 8th February 2012, enclosing a sample, relevant technical details and international conformity certificates for the **FIRE DAMPERS (MODELS: FDF & FDC)** manufactured by **Beta Industrial LLC, Dubai, United Arab Emirates.**

As the above mentioned products have been tested for 90 minutes fire resistance in accordance with the following authorities.

- 1) Underwriters Laboratories Inc. (UL) – Reference No: 20110322/R21930 dated 22.03.2011.
- 2) Dubai Civil Defence – (U.A.E) -Reference No: B17/1-1. Dated 19-10-2011.
- 3) Det Norske Veritas (DNV) Netherland – Reference No: 105463-2011-AQ-ARE-RVA. Dated: 03.11.2011.

Therefore, the General Directorate of Civil Defence has **NO OBJECTIONS** for the supply and installation of the **Smoke Dampers** within the Kingdom of Bahrain, subject to the compliance with all requirements set out in the manufacturer's specification.

It is clarified that this approval must not be treated as a blank approval for the supply and installation, project specific approval of this Directorate must be obtained prior to the commencement of installations.

Yours faithfully,

Lieut. Colonel
Director Protection & Safety Directorate
General Directorate of Civil Defence
Ali Mohammed Sa'ad Al-Hooti

